



## **MANUAL of DATALOGGER / WEBSEVER TYPE iBOX (with Ethernet)**

Version : jan 2009 version 2c

**SEE SEPARATE PROJECT SHEETS WITH SPECIFICATIONS OF THE SUPPLIED PROJECT  
like inputs, ranges, connections, passwords etc and ORDER list with ordered items**

- A.0 GENERAL DESCRIPTION & OPERATION
- A.1 CHANNEL SPECIFICATIONS
- A.2 MOUNTING AND CONNECTIONS
- A.3 SIGNAL CONDITIONING
- A.4 CALIBRATION
- A.5 CABINET & CABLE
- A.6 RECORD AND SAMPLE INTERVAL
- A.7 BATTERIES/POWER SUPPLY
- A.8 MEMORY
- A.9 SILICAGEL
- A.10 HOW TO USE SPLICE CONNECTORS FOR CABLE EXTENSION
- A.11 OTHER OPTIONS AND SPARE PARTS

Recommendation: adjust the logger with:

- sample interval standard 3 seconds
- record interval 10 minutes

## A.0 GENERAL DESCRIPTION & OPERATION of iBOX system

The iBOX is an easy-to-use, accurate and reliable **internet enabled datalogger system** with built-in web server with versatile inputs :1 up to 40 analog & digital inputs and serial inputs (optional wireless inputs) , see datasheet.

The iBOX **has integrated internet connectivity** with Ethernet connector and a **SD memory card** (128Mbyte up to 2 Gbyte) for data storage. Optional possibility: wirelessGPRS router for mobile or remote applications in Wireless WAN.

It is an essential tool for state of the art IP measurements for e.g. meteorology, environmental monitoring, wind energy feasibility studies, but also for general purpose projects: **complete systems according your requirements and specifications can be supplied!** Controlling and working with the IBOX is made easy with the built-in webserver (with help functions).

The iBOX logger configuration (number and type of input channels) and the logger parameters ( like sample and record interval) are stored on the SD memory card. Besides the logger configuration also the recorded data is secure stored at the SD card.

*From version 4 and later the iBOX the SD card can be programmed via a separate software package for adjusting parameters quickly (without using the webserver) like adjusting ip nr, subnet mask, gateway address (=address of router connected to internet)*

The logger configuration (which is stored at the SD card) can only be changed by EKOPOWER or by authorized users by using special iBOX control software ( menu part: logger configuration , password available from your supplier). In this menu can be set:

- ranges and units (preset at factory: do not change as this must be according to the physical inputs boards and connected sensors/signals!!)
- alarms: software alarms via e-mail
- timing variables (do not change)



The iBOX can send automatically data files via FTP to a specified server( e.g. the server of your website) at pre-adjusted intervals:

- file with instantaneous values and /or
- file with recorded values (eg average values with optional min/max/standard deviation during each record interval)

Moreover the data can be presented at a website with [webdisplays](#) or [online \(historical\) graphs](#), using graph hosting at our server.

The graphs can easily be integrated into your own website using copy and past of supplied html file.

EKOPOWER can supply standard graphs or design special graphs. Example of standard graphs:



By using the embedded webserver of the iBOX it is possible (by using your browser):

1. to set the logger parameters like:
  - time and date, sample and record interval
  - internet upload parameters: adjusting IP address of server (destination of data) , directory and the upload frequency of
    - > instantaneous & last recorded values values (and status): after adjustable number of samples (with optional online graphs, see [www.ekopower.net](#))
    - > recorded values (data files): after adjustable number of record intervals
2. Read current and last recorded values, the status of the system and the present logger configuration  
Note setting ip numbers of the iBOX itself can only be done with use of control software!

### Optional wireless connections:

- a) via WiFi wireless LAN (WLAN) or
- b) GPRS router (GPRS?HSDPA/3G) for Wireless WAN applications (WWAN)

**NOTE:** A different (but similar) design of the iBOX is the EKO21N, which has no Ethernet but serial RS232 / USB communication with ultra low power consumption (ideal for remote sites). EKO21N with optional GPRS internet connection (called EKO21N-iP) can send datafiles wireless to a specified server, with ultra low power consumption. By using a small battery pack it will operate during appr 5-10 years with one upload/day. Ask your supplier about the availability.

# ***EKOPOWER***

---

Measuring, Monitoring & Control Systems for Energy & Environment


For best possible performance of the system as a whole read this manual carefully before using the iBOX.

## How to get started?

Ethernet connection can be carried out in several ways:

### 1. Via direct cross cable:

#### How to use the iBOX Webserver over crosscable



#### Step 1


Make a direct connection between your iBOX and your PC with a cross-cable.

#### Step 2

Go to Start > (Settings) > Control Panel > Network Connection and click on the LAN pictogram.


#### Step 3

Click on the Properties pictogram.




## Step 4

Select the option Internet-protocol(TCP/IP) and then click on Properties.



## Step 5

Fill in the options given below and then click on OK. Click on OK again.



## Step 6

Test the communication between iBOX and the PC by entering the internal IP address of the supplied iBOX (default :http://10.0.0.174) in your browser. When the communication is OK picture in Step 7 will appear on the screen.

## Step 7

Fill in the Username and Password provided by Ekopower.



## Step 8



You have now entered the build-in Webserver inside the iBOX.

For more help about the Webserver you can refer to:


<http://www.ekopower.nl/manual-iBOX/webserver.html>

*\*) Internet browser: Internet Explorer, Mozilla Firefox, Opera or Netscape.*

## 2. Ethernet connection via LAN or WAN:

(for Connection to WiFi WLAN or Wireless WAN –WWAN- via GPRS/3G router refer to separate instructions)

How to use the iBOX Webserver over Local Area Network (LAN)  
and over the internet: Wide Area Network (WAN)



picture 1

### Step 1

Plug the iBOX in your router or modem.

### Step 2 (LAN Connection)

Test the communication between iBOX and a PC in the Local Area Network (LAN)

by entering the internal IP address of the supplied iBOX, eg : <http://10.0.0.174> your browser.

When the communication is OK picture 2 will appear on the screen, see step 4.

### Step 3 (WAN Connection)

Start your internet browser\* at a PC in the Local Area Network (LAN), select the internal network IP address of Router 1 (e.g. 10.0.0.138) and configure your router for the required NAT (port forwarding): Network Address (Port) Translation-settings, see picture 1.

Refer to the manual or help of your router. If the NAT is successfully entered, then you can reach the iBOX with the remote PC:

By entering the **external IP address of the router 1, followed by :80** (eg in the browser of the remote PC  
(see example 215.138.65.81:80) you will have direct contact with the iBOX webserver!

The external ip address of the router 1 can be obtained via a PC connected at router 1 and go to website  
eg : [http://www.ip-adress.com/ip\\_tracer/](http://www.ip-adress.com/ip_tracer/)

## Step 4

Fill in the username and password provided by Ekopower.



picture 2

## Step 5



picture 3

You have now entered the build-in Webserver inside the iBOX.

For more help about the Webserver you can refer to:

<http://www.ekopower.nl/manual-iBOX/webserver.html>

*\*) Internet browser: Internet Explorer, Mozilla Firefox, Opera or Netscape.*

## Additional notes about the operation with the iBOX

> 052\_current.log : file with current values ( 052= logger number)

> Data file name format:

The data file name format is: date time.log, e.g.: ascii datafile on the server: **i052-20060104144600.txt**

So in this case the file is made 4 january 2006 at 14h46, from ibox NUMBER 052 (written in advance specified directory!)

> Data files are in TEXT format, direct to import in Excel AND EASY TO COMBINE IN BIG FILE USING A TEXT EDITOR :copy/paste

> One logging is in most cases less then 100 bytes (depending on configuraion and resolution)

So the number of logging at one 128Mbyte SD card is appr 1.280.000 records.

If record interval is 10 minutes: a record period of 213000 hours (many years!)

> The upload frequency can also be changed using the optional iBOX control software (iBOX-EKO21N software),

menu: Change parameters – Ethernet settings

Afterwards the memory card needs to be prepared : choose Memory Card

(all new parameters are saved on the card and the logger reads this data at start-up)

> The default values for upload are:

- instanteneous values after each 200 samples: with sample interval 3 sec this result in one upload each 10 Minutes. For this upload interval (10 min) standard daily graphs are available from Ekopower.

- data files: after 144 records: with record interval of 10 minutes this result in a daily datafile upload (**note: file at least 512byte in size !**).

> FTP server and login properties should be entered

(ftp address, username and password of server: you may use the server of your website)

> HOW to find the outside iP adres of an internet connection /server? Use [http://www.ip-adress.com/ip\\_tracer/](http://www.ip-adress.com/ip_tracer/) or:

The iBOX logger configuration (ranges of input channels and the logger parameters, like sample and record interval)

are stored on the SD memory card. The logger configuration can only be changed by EKOPOWER or by authorized users by using the IBOX control software menu part: logger configuration (password available from your supplier). In this menu can be set:

- ranges and units (preset at factory: do not change as this must be according to the physical inputs boards and connected sensors/signals!!)

- alarms: software alarms via e-mail (or SMS using GPRS ) and hardware alarms: open collector output (if present in hardware)

- timing variables (do not change) **Always prepare card after changing parameters!!**

Note that input types cannot be changed or added in software: it must also be present in hardware!

## Install the control software (called: iBOX-EKO21N) for the iBOX on a windows PC

Note: this software is also for the EKO21N!

Installing the iBOX Control Software on a Windows 95/98/NT/2000/XP based PC.

Put the iBOX-EKO21N Control Program CD ROM in your CD drive.

Press the *START* button and choose the *RUN* option.

Select *Setup.EXE* and press the *OK* button.

The Install Wizard will guide you through the installation process.

**Tip:** When the Install Wizard prompts you for a destination directory in which to install the software  
change its name into a shorter and easier to use directory name by pressing the *Change Directory* button e.g. C:\iBOX-EKO21N  
(C:\ or D:\ depends on the hard drive you want to use).

After installing the Control Software you have to copy the supplied Configuration file into the same folder in which the iBOX-EKO21N Control Software is installed:

- iBOX with extension E (Ethernet)

eg: Configuration-E.173 (173 is logger identification code)

Using the Control Software for the first time

After installing the program you can start using the program.

Press the *START* button and choose *PROGRAMS*. Select the iBOX-EKO21N option to start the program.

(Refer to the Windows Help about making a shortcut to the Desktop).



## A.1 CHANNEL SPECIFICATIONS

>>> See separate sheet!

\*\*\* Password for change of channel specifications: on request

**DO NOT CHANGE CONFIGURATION AND RANGES WITHOUT CONSULTING YOUR SUPPLIER.**

### **Procedure for changing the sensor recalibration or exchange: (only for authorized users)**

When a calibrated sensor must be exchanged, the channel configuration should be changed of that logger, according to the calibration data.

Follow this procedure:

- \* download all old data from cards, using the **original** configuration
- \* choose Memory Card, logger configuration and enter the password (available from your supplier)
- \* select in channel configuration the corresponding pyranometer input channel
- enter new maximum of the range (see above)
- \* save the new configuration
- \* put the memory card of the logger in the SD Card slot of the PC
- \* prepare the card with the new configuration and put the memory card in the logger again

Example for anemometer:

### **Procedure for changing the anemometer calibration:**

When a calibrated anemometer must be exchanged, the channel configuration should be changed of that logger, according to the anemometer calibration data.

Follow this procedure:

- \* download all old data from cards, using the **original** configuration
- \* choose Memory Card, logger configuration and enter the password
- \* select in channel configuration the corresponding wind input channel
- note that: the calibration curve of a linear anemometer is expressed by: (refer to calibration certificate)  
 $v = af + b$       v=wind speed (m/s), a=slope, f = frequency (Hz), b=offset (m/s)  
so in order to calibrate the datalogger according to the calibration data of the anemometer:
  - enter the new offset of the new anemometer (e.g. 0.365 m/s)
  - enter new maximum of the range The new range for a calibrated anemometer is obtained by new slope multiplied by old range/0,77 (e.g. 50,45 m/s)
- For the MAX40+ anemometer with standard calibration is: offset = 0,4 , slope = 0,77 and range =50 m/s
- \* save the new configuration
- \* put the memory card of the logger in the SD Card slot of the PC
- \* prepare the card with the new configuration and put the memory card in the logger again

## A.2 MOUNTING AND CONNECTIONS

The installation is very simple and is carried out in the following steps:

- Mount cabinet at DIN rail (or in extra cabinet with DIN rail)
- Connect sensors and signals, according to separate connection diagram and connect external power supply
- Prepare memory card if not already done and put (prepared) SD memory card in slot (supplied with iBOX)
- Connect the Ethernet connector to a network (see next chapters)

If the iBOX datalogger is placed in the field, it should be protected against vandalism and harsh environmental conditions (direct sunshine, rain etc.) The best solution is to place the logger in an additional case with lock, which can also be supplied by Ekopower. The cabinet can be fixed to a wall or pole, with cable plugs faced to ground. Always close the cabinet carefully before you leave.

Some general used sensors are: (refer to your order list and our website for more details of the sensors )

- wind speed : MAXIMUM, type 40+
- wind direction : DIR 21+ (low cost), both with long-life potentiometer
- temp/humidity : TS21 and HUM21 with precision thermistor for temperature

For windvane DIR 21+: The > mark at the windvane should be directed to **South** (equal to 180 degrees).

Or direct upper part of the vane to south and turn lower part of the vane, so the reading (at the display of the PC with serial connection) is 180 degrees. Then fix the bold.

Use a compass and/or map to determine South and North. Do not use the compass close to metal!!

Use the waterproof cable connector to extend the cable (if ordered), see also part A.14.

The radiation shield ("weather screen") of the temperature/humidity sensor can be mounted at the mast by using the stainless steel mast clamps.

Booms, mounting brackets (see also Universal Sensor Mounting Arm)

If the windvane is mounted at a boom of a mast, mount the vane so that the vane is in the right position after erection of the mast ! For mounting the vane to a boom of a mast an extra mounting adaptor can be supplied.


Fix the booms to the mast using the mast mounting materials (stainless steel mast clamps).

For detailed instructions for mounting the mast refer to the manual of the mast.

Although the iBOX is protected against overvoltage, the additional lightning conductor will protect the instrument better against close atmospheric discharges.

If a Wind Energy Conversion System (WECS) is monitored follow the recommendations of the IEA, concerning the position of the sensors. If the system is equipped with sensors for (air) temperature, rel. humidity, atm. pressure a.s.o., place these sensors in a weather screen. Mount the cabinet with cable inputs faced to ground.

## CONNECTIONS



### Input Connections

Open the extra case (if supplied). Now the connectors of the IBOX are accessible.

The cable should be connected to these connectors. First put the cable through the plugs of the extra cabinet.

Connect the cable, according to the separate connection table.

Insert the wires into the screw connectors (with wire protection is recommended!).

Take your time for connecting the sensors and transducers to the datalogger system.

Wrong connections can result in wrong measurements!

Connections of the SENSORS: **>>>SEE SEPARATE PROJECT SPECIFICATION SHEET!**

Calibrated sensors should be connected to the right datalogger and input: refer to calibration reports and connection table at the datalogger

Cables may be extended using the connection kit with waterproof wire isolation.

Connections to the computer or network: via Ethernet cable.

### A.3 SIGNAL CONDITIONING

The average values are determined using the sample technique; for the determination of the average wind direction the discontinuity at 0-360 degr. is taken in account (polar averaging).

The maximum gust is determined by measuring the 1 sec average value of the wind speed during the record interval.

Note that the record interval is the same for all the channels in use, so after each record interval the channels are recorded simultaneously

Instantaneous values can be read using the iBOX webserver, this is ALSO possible during recording.

The instantaneous value of integrating inputs (e.g. pulscount) is the current value of the integrator at the end of the record interval.

"Instantaneous" values of maximum, standard deviation are not available during the meter function as they are determined (and recorded) at the end of each record interval.

Instead of average values also "instantaneous" values can also be logged.

In that case there is only 1 sample during the record interval. Only after each record interval a sample is recorded in that case.

**EKOPOWER**

Measuring, Monitoring & Control Systems for Energy & Environment

SEE THE ORDER SHEET FOR SPECIFICATIONS OF THE POSSIBLE extra ITEMS.

## **A.4 CALIBRATION CERTIFICATE**

Sensors are calibrated according to factory standard calibration or according to ordered calibration certificate.

## **A.5 CABINET & CABLE**

- extra cabinet (stainless steel/polyester)
- cable:

## **A.6 RECORD AND SAMPLE INTERVAL**

Record interval: adjustable, sample interval: adjustable

## **A.7 BATTERIES/POWER -supply :**

The iBOX has external power supply usual 5-6V (depending on configuration!)

## **A.8 MEMORY**

\* non volatile PREPARED SD card (standard 128 MByte)

Size: o 64 Mb o 128 Mb o 256Mb o 512 Mb o 1GB o 2GB

SD reader for notebook (PCCARD to SD adaptor) or for PC (USB) external SD card drive is available

## **A.9 SILICAGEL**

In order to keep the humidity inside the cabinet at a low level a set of dessicators (which are filled with active silicagel) is placed in the cabinet. The dessicators has to be replaced by (supplied) regenerated ones at the start of the datalogger operation. Replacement has also to take place if the enclosed humidity indicator (at the upper cover of the cabinet) is turning to a light-red colour instead of blue. The time in which this may occur depends of the local climatic circumstances, but should be at least one month in very hot and humid environments. The dessicators can be replaced by taking them out of the cabinet. A dessicator can be regenerated in a stove at a temperature < 130 C. Keep it dry by storing it in a well closed plastic bag. It is recommended to replace the dessicator at the same time when the batteries are replaced.

## A.10 HOW TO USE THE WATERPROOF SPLICE CONNECTORS FOR CABLE EXTENSIONS

- for reliable, easy and quick cable connections-

Use them as follows:

0. Open the connector by turning counter clockwise and take out the wire splice connectors.
1. Strip the outside isolation of the cables over a length of about 4 cm.
2. Do NOT strip the individual wires!!
3. Take a (un-striped) wire from one of the cables and place it in one of the holes of a splice connector.

Make sure you pushed the wire all the way in!


You can check this by looking through the clear side of the splice connector.

**IF shielded cable: connect shields to screw connector!**

4. Take the corresponding wire from the other cable and place it (also un-striped) in the other hole of the splice connector, which you used in step 3.
5. Use a set of pliers to snap the yellow cap into the splice connector, press for securing the wires. Press firmly so the wires are fixed.
6. Repeat steps 3-5 for the other wires.
7. Close the connector by turning clockwise. Fix the connector e.g. with 2 ty-raps.
8. Fasten the cable plugs (do not turn the cables)

For the best and most reliable connections note the following recommendations:

- \* Do not dig this connection in the ground
- \* Fasten the box and the cable using ty raps, so the cables cannot move.
- \* It is a good practical to leave an extra length of cable, for future use and for fixing the cable together.



## **A.11 OTHER OPTIONS, SPARE PARTS & ACCESSORIES: (SPECIFY AT ORDER) see also [www.ekopower.nl](http://www.ekopower.nl)**

- \* sensors and transducers (for all kinds of applications)
- \* extra weather screen and/or "vandalism resistant" cabinet for IBOX
- \* for air temperature and/or humidity sensor: small weather screen
- \* connection cables from IBOX to computer
- \* WiFi module
- \* routers wireless (GPRS/3G)
- \* remote alarm reporting feature
- \* online webdisplay and online graphs
- \* notebook PC with SD Card drive
- \* SD Card drive (USB)
- \* solar power supply including backup
- \* 220 V AC adaptor with power line filter
- \* standard software for dataprocessing
- \* meteo-mast for sensors
- \* batteries
- \* testplugs, extra dessicators, cable for sensors

## **IMPORTANT INSTRUCTIONS**

### **To start operation:**

1. Make all sensor input connections
2. Check if a prepared SD memory card in the iBOX slot
3. Apply power
4. Check the green LED is flashing: OK
5. Connect to LAN or WAN